



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
OUELLET, JIM
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 02/06/2018
Report ID# : 20180206104726AE09818

Lab Sample ID# : AE09818
Sample Priority : NORMAL
TCEQ ID#(s) : 1841894

Water Source :
Entry Point(s) : DBP2-02

Date Collected : 01/23/2018 10:36
Date Received : 01/24/2018
Date Analyzed : 01/25/2018

Conc. Units : µg/L
Method : EPA 524.2
Analyst : LZ
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (2.7), Bromodichloromethane (5.0), Dibromochloromethane (7.6), Bromoform (3.6), and Total Trihalomethanes 1 (18.9).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 02/06/2018

RECEIVED
FEB 12 2018
BUNNELL #2



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

FEB 25 2018

BASTROP COUNTY WCID 2
OUELLET, JIM
PO BOX 708
BASTROP, TX 78602-0708

BCWCID #2

Date Reported : 02/20/2018
Report ID# : 20180220103809AE09841

Lab Sample ID# : AE09841
Sample Priority : NORMAL
TCEQ ID#(s) : 1841893

Water Source :
Entry Point(s) : DBP2-01

Date Collected : 01/23/2018 10:09
Date Received : 01/24/2018
Date Analyzed : 01/26/2018

Conc. Units : µg/L
Method : EPA 524.2
Analyst : LZ
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (<1.0), Bromodichloromethane (1.6), Dibromochloromethane (2.3), Bromoform (1.5), and Total Trihalomethanes 1 (5.4).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III AMIERTSCH on 02/20/2018



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

RECEIVED
FEB 25 2018
BOWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
OUELLET, JIM
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 02/20/2018
Report ID# : 20180220103809AE09841

Lab Sample ID# : AE09841 Water Source : Date Collected : 01/23/2018 10:09 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-01 Date Received : 01/24/2018 Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1841893 Date Analyzed : 02/06/2018 Analyst : TH
Extraction Date : 02/05/2018 Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Monochloroacetic acid, Dichloroacetic acid, Trichloroacetic acid, Monobromoacetic acid, Dibromoacetic acid, and Total HAA5.

Table with 3 columns: Monitored Compounds, Result, Qualifier. Rows include Bromochloroacetic acid and Dalapon.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III AMIERTSCH on 02/20/2018



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Haloacetic Acids Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
OUELLET, JIM
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 02/06/2018
Report ID# : 20180206104726AE09818

Lab Sample ID# : AE09818	Water Source :	Date Collected : 01/23/2018 10:36	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : DBP2-02	Date Received : 01/24/2018	Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1841894		Date Analyzed : 01/26/2018	Analyst : TH
		Extraction Date : 01/25/2018	Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Monochloroacetic acid	<2.0	
Dichloroacetic acid	1.5	
Trichloroacetic acid	<1.0	
Monobromoacetic acid	<1.0	
Dibromoacetic acid	1.6	
Total HAA5 ¹	3.1	
Monitored Compounds	Result	Qualifier
Bromochloroacetic acid	1.5	
Dalapon	<1.0	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 02/06/2018

RECEIVED
FEB 12 2018
BOWCID #2