



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

RECEIVED
JUN 11 2018
BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 05/15/2018
Report ID# : 20180515094705AE22020

Lab Sample ID# : AE22020
Sample Priority : NORMAL
TCEQ ID#(s) : 1845033

Water Source :
Entry Point(s) : DBP2-02

Date Collected : 04/11/2018 10:57
Date Received : 04/12/2018
Date Analyzed : 04/17/2018

Conc. Units : µg/L
Method : EPA 524.2
Analyst : KL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (<1.0), Bromodichloromethane (2.3), Dibromochloromethane (4.4), Bromoform (2.9), and Total Trihalomethanes 1 (9.6).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(\*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 05/10/2018



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 05/15/2018
Report ID# : 20180515094705AE22020

Lab Sample ID# : AE22020
Sample Priority : NORMAL
TCEQ ID#(s) : 1845033

Water Source :
Entry Point(s) : DBP2-02

Date Collected : 04/11/2018 10:57
Date Received : 04/12/2018
Date Analyzed : 04/19/2018
Extraction Date : 04/17/2018
Conc. Units : µg/L
Method : 552.2 Rev 1.0
Analyst : TH
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Monochloroacetic acid, Dichloroacetic acid, Trichloroacetic acid, Monobromoacetic acid, Dibromoacetic acid, Total HAA5) and Monitored Compounds (Bromochloroacetic acid, Dalapon).

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(\*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 05/10/2018



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 05/15/2018
Report ID# : 20180515094705AE22021

Lab Sample ID# : AE22021
Sample Priority : NORMAL
TCEQ ID#(s) : 1845032

Water Source :
Entry Point(s) : DBP2-01

Date Collected : 04/11/2018 11:17
Date Received : 04/12/2018
Date Analyzed : 04/18/2018
Extraction Date : 04/17/2018
Conc. Units : µg/L
Method : 552.2 Rev 1.0
Analyst : TH
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Monochloroacetic acid, Dichloroacetic acid, Trichloroacetic acid, Monobromoacetic acid, Dibromoacetic acid, Total HAA5) and Monitored Compounds (Bromochloroacetic acid, Dalapon).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(\*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 05/10/2018



Texas Department of State Health Services

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Volatile Organic Compounds by GC/MS  
 Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
 CREAMER, JOHN  
 PO BOX 708  
 BASTROP, TX 78602-0708

Date Reported : 05/15/2018

Report ID#: 20180515094705AE22095

Lab Sample ID# : AE22095  
 Sample Priority : NORMAL  
 TCEQ ID#(s) : 1801620

Water Source :  
 Entry Point(s) : EP001

Date Collected : 04/11/2018 11:39  
 Date Received : 04/12/2018  
 Date Analyzed : 04/19/2018

Conc. Units : µg/L  
 Method : EPA 524.2  
 Analyst : MA  
 Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene <sup>1</sup>	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride <sup>1</sup>	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene <sup>1</sup>	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene <sup>1</sup>	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene <sup>1</sup>	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane <sup>1</sup>	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene <sup>1</sup>	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene <sup>1</sup>	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene <sup>1</sup>	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane <sup>1</sup>	<0.5		t-Butylbenzene	<1.0	
Dichloromethane <sup>1</sup>	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene <sup>1</sup>	<0.5		Trichlorofluoromethane	<2.0	
Styrene <sup>1</sup>	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene <sup>1</sup>	<0.5		Bromochloromethane	<1.0	
Toluene <sup>1</sup>	<0.5		<b>Other Compounds</b>	<b>Result</b>	<b>Qualifier</b>
1,2,4-Trichlorobenzene <sup>1</sup>	<0.5		Acetone	<10	
1,1,1-Trichloroethane <sup>1</sup>	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane <sup>1</sup>	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene <sup>1</sup>	<0.5		Carbon disulfide	<1.0	
Vinyl chloride <sup>1</sup>	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) <sup>1</sup>	<0.5		2-Hexanone	<1.0	
<b>Monitored Cmpds.[40 CFR 141.40(e)]</b>	<b>Result</b>	<b>Qualifier</b>	Iodomethane	<5.0	G
Chloroform	1.8		Methyl methacrylate	<1.0	
Bromodichloromethane	3.4		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	5.5		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	2.7		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		<b>Comments:</b>		
1,3-Dichlorobenzene	<1.0		G - CCV/LFB recovery was below method acceptance limits.		
1,1-Dichloropropene	<1.0		The test results on this report relate only to the sample		
1,1-Dichloroethane	<1.0	G	identified on this report. The test results for analytes noted(1)		
1,1,2,2-Tetrachloroethane	<1.0		meet all TNI (2009 Standard) requirements.		
1,3-Dichloropropane	<1.0		Authorized by Group Manager TDUNN on 05/10/2018		
Chloromethane	<2.0				
Bromomethane	<2.0	G			
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				





# Texas Department of State Health Services

PO BOX 149347  
AUSTIN, TEXAS 78714-9347  
1-888-963-7111  
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947  
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

## Pesticides by Method 508.1 Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
CREAMER, JOHN  
PO BOX 708  
BASTROP, TX 78602-0708

Date Reported : 05/24/2018  
Report ID# : 20180524091606AE22130

Lab Sample ID# : AE22130      Water Source :  
Sample Priority : NORMAL      Entry Point(s) : EP001  
TCEQ ID#(s) : 1807241

Date Collected : 04/11/2018 11:39      Conc. Units : ug/L  
Date Received : 04/12/2018      Method : 508.1 Rev. 2.0  
Date Analyzed : 04/23/2018      Analyst : CL  
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Chlordane <sup>1</sup>	<0.20	
Endrin <sup>1</sup>	<0.01	
Heptachlor epoxide <sup>1</sup>	<0.02	
Toxaphene <sup>1</sup>	<1.0	

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(<sup>1</sup>) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III TBOROWSKI on 05/22/2018

**RECEIVED**  
JUN 08 2018  
BCWCID #2



Texas Department of State Health Services

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Volatile Organic Compounds by GC/MS  
 Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
 CREAMER, JOHN  
 PO BOX 708  
 BASTROP, TX 78602-0708

Date Reported : 05/15/2018  
 Report ID#: 20180515094705AE22079

Lab Sample ID#: AE22079  
 Sample Priority : NORMAL  
 TCEQ ID#(s) : 1804279

Water Source :  
 Entry Point(s) : EP002

Date Collected : 04/11/2018 10:13  
 Date Received : 04/12/2018  
 Date Analyzed : 04/18/2018  
 Conc. Units : µg/L  
 Method : EPA 524.2  
 Analyst : MA  
 Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene <sup>1</sup>	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride <sup>1</sup>	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene <sup>1</sup>	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene <sup>1</sup>	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene <sup>1</sup>	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane <sup>1</sup>	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene <sup>1</sup>	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene <sup>1</sup>	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene <sup>1</sup>	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane <sup>1</sup>	<0.5		t-Butylbenzene	<1.0	
Dichloromethane <sup>1</sup>	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene <sup>1</sup>	<0.5		Trichlorofluoromethane	<2.0	
Styrene <sup>1</sup>	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene <sup>1</sup>	<0.5		Bromochloromethane	<1.0	
Toluene <sup>1</sup>	<0.5				
1,2,4-Trichlorobenzene <sup>1</sup>	<0.5		<b>Other Compounds</b>	<b>Result</b>	<b>Qualifier</b>
1,1,1-Trichloroethane <sup>1</sup>	<0.5		Acetone	<10	
1,1,2-Trichloroethane <sup>1</sup>	<0.5		Acrylonitrile	<10	
Trichloroethylene <sup>1</sup>	<0.5		2-Butanone (MEK)	<10	
Vinyl chloride <sup>1</sup>	<0.5		Carbon disulfide	<1.0	
Xylenes (total) <sup>1</sup>	<0.5		Ethyl methacrylate	<1.0	
			2-Hexanone	<1.0	
<b>Monitored Cmpds.[40 CFR 141.40(e)]</b>	<b>Result</b>	<b>Qualifier</b>	Iodomethane	<5.0	G
Chloroform	<1.0		Methyl methacrylate	<1.0	
Bromodichloromethane	<1.0		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	1.3		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	1.1		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0				
1,3-Dichlorobenzene	<1.0		<b>Comments:</b>		
1,1-Dichloropropene	<1.0		G - CCV/LFB recovery was below method acceptance limits.		
1,1-Dichloroethane	<1.0		The test results on this report relate only to the sample		
1,1,2,2-Tetrachloroethane	<1.0		identified on this report. The test results for analytes noted(!)		
1,3-Dichloropropane	<1.0		meet all TNI (2009 Standard) requirements.		
Chloromethane	<2.0		<b>Authorized by Group Manager TDUNN on 05/10/2018</b>		
Bromomethane	<2.0	G			
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				



**Texas Department of State Health Services**

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

**Semivolatiles Organic  
 Analysis Report**

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
 CREAMER, JOHN  
 PO BOX 708  
 BASTROP, TX 78602-0708

Date Reported : 05/24/2018  
 Report ID#: 20180524091606AE22128

Lab Sample ID#: AE22128  
 Sample Priority : NORMAL  
 TCEQ ID#(s) : 1808531

Water Source :  
 Entry Point(s) : EP002

Date Collected : 04/11/2018 10:14  
 Date Received : 04/12/2018  
 Date Analyzed : 04/18/2018  
 Extraction Date : 04/16/2018  
 Conc. Units : µg/L  
 Method : EPA 525.2  
 Analyst : JO  
 Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor	<0.2		Dimethylphthalate	<2.0	
Atrazine	<0.1		Fluorene	<0.20	
Benzo[a]pyrene	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.50	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.20	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.20	
trans-Nonachlor	<0.2		Metolachlor	<0.20	
Di(2-ethylhexyl) adipate	<0.6		Metribuzin	<0.20	
Di(2-ethylhexyl) phthalate	<0.6		Naphthalene	<0.20	
Heptachlor	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.50	
Hexachlorobenzene	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.20	
Hexachlorocyclopentadiene	<0.1	*	Phenanthrene	<0.20	
Lindane	<0.02		Propachlor	<0.20	
Methoxychlor	<0.1		Pyrene	<0.20	
Simazine	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.20	
<b>Monitored Compounds</b>	<b>Result</b>	<b>Qualifier</b>	2,4,5-Trichlorobiphenyl	<0.20	
Acenaphthene	<0.20		Trifluralin	<0.20	
Acenaphthylene	<0.20		<b>Comments:</b>		
Aldrin	<0.20		* - This analyte has known instability and/or method performance issues and quantitation should be considered approximate.		
Anthracene	<0.20		The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.		
Benzo(a)anthracene	<0.20		Authorized by Chemist III TBOROWSKI on 05/22/2018		
Benzo[b]fluoranthene	<0.20				
Benzo[g,h,i]perylene	<0.20				
Benzo[k]fluoranthene	<0.20				
Bromacil	<0.20				
Butachlor	<0.20				
Butylbenzylphthalate	<2.0				
2-Chlorobiphenyl	<0.20				
Chrysene	<0.20				
Dibenz[a,h]anthracene	<0.20				
Di-n-butylphthalate	<2.0				
2,3-Dichlorobiphenyl	<0.20				
Dieldrin	<0.20				
Diethylphthalate	<2.0				





**Texas Department of State Health Services**

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**Volatile Organic Compounds by GC/MS  
 Analysis Report**

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
 CREAMER, JOHN  
 PO BOX 708  
 BASTROP, TX 78602-0708

Date Reported : 05/15/2018  
 Report ID# : 20180515094705AE22083

Lab Sample ID# : AE22083      Water Source :      Date Collected : 04/11/2018 10:41      Conc. Units : µg/L  
 Sample Priority : NORMAL      Entry Point(s) : EP004      Date Received : 04/12/2018      Method : EPA 524.2  
 TCEQ ID#(s) : 1805836      Date Analyzed : 04/18/2018      Analyst : MA  
 Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene <sup>1</sup>	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride <sup>1</sup>	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene <sup>1</sup>	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene <sup>1</sup>	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene <sup>1</sup>	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane <sup>1</sup>	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene <sup>1</sup>	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene <sup>1</sup>	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene <sup>1</sup>	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane <sup>1</sup>	<0.5		t-Butylbenzene	<1.0	
Dichloromethane <sup>1</sup>	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene <sup>1</sup>	<0.5		Trichlorofluoromethane	<2.0	
Styrene <sup>1</sup>	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene <sup>1</sup>	<0.5		Bromochloromethane	<1.0	
Toluene <sup>1</sup>	<0.5		<b>Other Compounds</b>	<b>Result</b>	<b>Qualifier</b>
1,2,4-Trichlorobenzene <sup>1</sup>	<0.5		Acetone	<10	
1,1,1-Trichloroethane <sup>1</sup>	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane <sup>1</sup>	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene <sup>1</sup>	<0.5		Carbon disulfide	<1.0	
Vinyl chloride <sup>1</sup>	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) <sup>1</sup>	<0.5		2-Hexanone	<1.0	
<b>Monitored Cmpds.[40 CFR 141.40(e)]</b>	<b>Result</b>	<b>Qualifier</b>	Iodomethane	<5.0	G
Chloroform	15		Methyl methacrylate	<1.0	
Bromodichloromethane	11		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	6.8		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	<1.0		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		<b>Comments:</b>		
1,3-Dichlorobenzene	<1.0		G - CCV/LFB recovery was below method acceptance limits.		
1,1-Dichloropropene	<1.0		The test results on this report relate only to the sample		
1,1-Dichloroethane	<1.0		identified on this report. The test results for analytes noted(1)		
1,1,2,2-Tetrachloroethane	<1.0		meet all TNI (2009 Standard) requirements.		
1,3-Dichloropropane	<1.0		<b>Authorized by Group Manager TDUNN on 05/10/2018</b>		
Chloromethane	<2.0				
Bromomethane	<2.0	G			
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				





**Texas Department of State Health Services**

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

**Semivolatiles Organic  
 Analysis Report**

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2  
 CREAMER, JOHN  
 PO BOX 708  
 BASTROP, TX 78602-0708

Date Reported : 05/24/2018  
 Report ID# : 20180524091606AE22131

Lab Sample ID# : AE22131      Water Source :      Date Collected : 04/11/2018 10:41      Conc. Units : µg/L  
 Sample Priority : NORMAL      Entry Point(s) : EP004      Date Received : 04/12/2018      Method : EPA 525.2  
 TCEQ ID#(s) : 1808085      Date Analyzed : 04/18/2018      Analyst : JO  
 Extraction Date : 04/16/2018      Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor	<0.2		Dimethylphthalate	<2.0	
Atrazine	<0.1		Fluorene	<0.20	
Benzo[a]pyrene	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.50	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.20	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.20	
trans-Nonachlor	<0.2		Metolachlor	<0.20	
Di(2-ethylhexyl) adipate	<0.6		Metribuzin	<0.20	
Di(2-ethylhexyl) phthalate	<0.6		Naphthalene	<0.20	
Heptachlor	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.50	
Hexachlorobenzene	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.20	
Hexachlorocyclopentadiene	<0.1	*	Phenanthrene	<0.20	
Lindane	<0.02		Propachlor	<0.20	
Methoxychlor	<0.1		Pyrene	<0.20	
Simazine	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.20	
<b>Monitored Compounds</b>	<b>Result</b>	<b>Qualifier</b>	2,4,5-Trichlorobiphenyl	<0.20	
Acenaphthene	<0.20		Trifluralin	<0.20	
Acenaphthylene	<0.20				
Aldrin	<0.20				
Anthracene	<0.20				
Benzo(a)anthracene	<0.20				
Benzo[b]fluoranthene	<0.20				
Benzo[g,h,i]perylene	<0.20				
Benzo[k]fluoranthene	<0.20				
Bromacil	<0.20				
Butachlor	<0.20				
Butylbenzylphthalate	<2.0				
2-Chlorobiphenyl	<0.20				
Chrysene	<0.20				
Dibenz[a,h]anthracene	<0.20				
Di-n-butylphthalate	<2.0				
2,3-Dichlorobiphenyl	<0.20				
Dieldrin	<0.20				
Diethylphthalate	<2.0				

**Comments:**  
 \* - This analyte has known instability and/or method performance issues and quantitation should be considered approximate.  
 The test results on this report relate only to the sample identified on this report. The test results for analytes noted(!) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III TBOROWSKI on 05/22/2018

RECEIVED  
 JUN 11 2018  
 BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Pesticides by Method 508.1
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 05/24/2018
Report ID# : 20180524091606AE22131

Lab Sample ID# : AE22131 Water Source : Date Collected : 04/11/2018 10:41 Conc. Units : ug/L
Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 04/12/2018 Method : 508.1 Rev. 2.0
TCEQ ID#(s) : 1808085 Date Analyzed : 04/23/2018 Analyst : CL
Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Chlordane, Endrin, Heptachlor epoxide, and Toxaphene.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III TBOROWSKI on 05/22/2018

RECEIVED
JUN 11 2018
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 05/15/2018
Report ID# : 20180515094705AE22021

Lab Sample ID#: AE22021 Water Source : Date Collected : 04/11/2018 11:17 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-01 Date Received : 04/12/2018 Method : EPA 524.2
TCEQ ID#(s) : 1845032 Date Analyzed : 04/18/2018 Analyst : KL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (<1.0), Bromodichloromethane (1.4), Dibromochloromethane (3.0), Bromoform (2.7), and Total Trihalomethanes 1 (7.1).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 05/10/2018